



**IBAAAN ELECTRIC CORPORATION**  
 Metro-Rei Business Park, Palindan,  
 Ibaan, Batangas  
 Tel.no:(043)311-2390  
 Cel.no.:0949-722-4771 / 0939-924-9478  
 0920-893-0256

"Your Partner to a Brighter Tomorrow"

**BID BULLETIN NO. 01**  
**"Procurement of Supply and Delivery of Various Materials"**  
 (ITB NO. 2024-002)


This Bid Bulletin No.1 is being issued to clarify/ amend certain provisions contained in the Bidding Documents for this procurement in the **Pre-Bid Conference** conducted last **December 03, 2024**.

Provision			Amendment		
<b>Lot 02 – Procurement of Supply and Delivery of Protection Devices and Equipments</b>					
<b>II. Terms of Reference</b>			<b>II. Terms of Reference</b>		
<b>B. Technical Specifications</b>			<b>B. Technical Specifications</b>		
The offered product must comply with the following standards as indicated in this portion of the bidding documents and other related IEC and ANSI Standard.			The offered product must comply with the following standards as indicated in this portion of the bidding documents and other related IEC and ANSI Standard.		
<b>I.High Voltage Power Capacitor</b>			<b>I.High Voltage Power Capacitor</b>		
a.	Standard:	IEC 61000-4-30	a-	<del>Standard:</del>	<del>IEC 61000-4-30</del>
b.	Country of Origin:	All countries, except China	a.	Standard:	IEC 60871
c.	Standard:	IEC 60871	b.	Country of Origin:	All countries, except China
d.	KVAR Rating:	25 KVAR (Single Phase)	c.	KVAR Rating:	25 KVAR (Single Phase)
e.	Rated Voltage:	7620 V	d.	Rated Voltage:	7620 V
f.	Basic Insulation Level (BIL):	95 kV	e.	Basic Insulation Level (BIL):	95 kV
g.	Capacitance Tolerance:	-5% to +10%	f.	Capacitance Tolerance:	-5% to +10%
h.	Maximum Permissible Voltage:	110% of the Rated Voltage	g.	Maximum Permissible Voltage:	110% of the Rated Voltage
i.	Maximum Permissible Current:	135% of the Rated Voltage	h.	Maximum Permissible Current:	135% of the Rated Voltage
j.	Dissipation Factor:	Less than 0.05%	i.	Dissipation Factor:	Less than 0.05%
k.	Ambient Temperature:	-25°C to +50°C	j.	Ambient Temperature:	-25°C to +50°C
l.	Rated Frequency:	60 hz	k.	Rated Frequency:	60 hz
m.	Installation:	Outdoor; Pole Mounting	l.	Installation:	Outdoor; Pole Mounting

The amendment to the provision stated above will apply to the bidding documents and other information specified therein.

For guidance and information of all concerned.

Issued this Friday, December 06, 2024.

  
**ENGR. DANIEL VINCENT C. DE LA ROSA**  
 Chairman, Bids and Awards Committee

  
 ETP/LAL/RWM/JPF