



## IBAAN ELECTRIC CORPORATION

Metro-Rei Business Park, Palindan,  
Ibaan, Batangas  
Tel.no:(043)311-2390  
Cel.no.:0949-722-4771 / 0939-924-9478  
0920-893-0256

"Your Partner to a Brighter Tomorrow"

### BID BULLETIN NO. 02 "ENGINEERING, PROCUREMENT AND CONSTRUCTION OF PALINDAN SUBSTATION EXPANSION PROJECT - TURNKEY"

(ITB NO. 2025-002)

This Bid Bulletin No. 2 is being issued to amend certain provisions contained in the Bidding Documents for this procurement in response to the queries raised by the prospective bidders in the **Pre-Bid Conference** conducted last **December 02, 2025**.

ITEM NO.	REFERENCE	QUERIES	AMENDMENT/RESPONSE
1.	<i>The total project duration shall be a maximum of <b>six (6) months, or as may be offered by the bidder as the best completion period, to be counted from the date of issuance of the Notice to Proceed.</b></i>	Asked if the project duration may be extended beyond six (6) months.	Ms. Panday clarified that the project duration must strictly follow the maximum of six (6) months or best offer as stated in the bidding documents.
2.	<b>APPROVED BUDGET COST (ABC) : Php 69,471,146.14</b>	Inquired whether the project already has an available budget.	Ms. Panday confirmed with a "Yes."
3.	<b>Down Payment - 10%</b> <i>A down payment equivalent to ten percent (10%) of the Contract Price shall be released to the Contractor upon issuance of the Notice to Proceed (NTP) and submission of all required documentation for advance payment.</i>	Asked if 15% down payment is possible.	Ms. Panday confirmed that only a 10% down payment of the contract price, upon issuance of the NTP, is allowed as indicated in the bid documents.
4.	<b>Supply, Delivery, Installation, Testing, and Commissioning of 20/25MVA Power Transformer 69kV - 13.2kV</b> Country of Orig in : <b>Except China and Korea</b>	Regarding the transformer, it is indicated that procurement from China is not allowed. May we still purchase from China to reduce costs?	Mr. Sale explained that although it was previously recommended, the final management approval did not allow procurement from China; therefore, they will strictly adhere to the TOR.



## IBAAN ELECTRIC CORPORATION

Metro-Rei Business Park, Palindan,  
Ibaan, Batangas  
Tel.no: (043)311-2390  
Cel.no.: 0949-722-4771 / 0939-924-9478  
0920-893-0256

"Your Partner to a Brighter Tomorrow"


5.	<p>Supply, Delivery and Installation of 69kV and 15kV Gantry (Steel Structure)</p> <p><i>8. Design must be identical to existing structure</i></p>	<p>For the steel structure design, they asked if they may provide a different design.</p>	<p>Mr. Sale responded that they will adhere to the TOR, which requires a design identical to the existing structure.</p>
6.	<p><b>a. Legal Documents (Folder 1)</b></p> <p><i>i. Registration Certificate (DTI or SEC).</i></p> <p><i>ii. Mayor's/Business Permit, or equivalent document for entities operating within Exclusive Economic Zones or Areas.</i></p> <p><i>iii. BIR Certificate of Registration.</i></p> <p><i>iv. Current Tax Clearance Certificate.</i></p> <p><b>v. Valid PCAB License - with at least License Category of B</b></p>	<p>Since our license is still under renewal, can we submit our PCAB License application form?</p>	<p>In lieu of the required document, you may submit an Affidavit of Undertaking with a copy of the Application Form, as may be appropriate.</p>

*The amendments to the provision stated above will apply to the bidding documents and other information specified therein.*

For guidance and information of all concerned.

Issued this Friday, December 05, 2025.

  
**MS. EYLEN T. PANDAY**  
Chairperson, Bids and Awards Committee

  
LAL AMAL/NBP/MLM